EFECTIS ERA AVRASYA TEST ve BELGELENDİRME AŞ
Dilovası OSB Mahallesi Fırat Caddesi No: 18
Dilovası, Kocaeli / TÜRKİYE
www.efectis.com

DECLARATION OF TEST RESULTS

No: ERA – 2300 – 0049

The related reaction to fire tests were carried out for the product as described below at Efectis Era Avrasya Test Laboratory 15 of December 2023. Classification of reaction to fire has been carried out in accordance the standard:

EN 13501-1:2018

‘‘Waterproofing Covering - 110 g/m²’’

Fire behaviour		Smoke production			Flaming droplets	
B	-	s	1	,	d	0

Flammability Classification*
Hardly inflammable

*Turkey’s regulation on fire protection 2009, Appendix-2/Ç the table of flammability classification of construction materials in accordance with EN 13501-1

Placed on the market by: BAŞAT TEKSTİL İNŞ. VE İNŞ. MALZ. İZOL. SAN. DIŞ. TİC. LTD. ŞTİ. İkitelli OSB Mah. Sefaköy San. Sit. 7. Blok No:7 Başakşehir, İstanbul / TÜRKİYE

Manufactured by: BAŞAT TEKSTİL İNŞ. VE İNŞ. MALZ. İZOL. SAN. DIŞ. TİC. LTD. ŞTİ. İkitelli OSB Mah. Sefaköy San. Sit. 7. Blok No:7 Başakşehir, İstanbul / TÜRKİYE

e-signed

Ali BAYRAKTAR
Laboratory Manager
08.02.2024

This document is a declaration of test results and does not represent any type of approval or certification of the product. All details related to product specifications and field of applications are described in the reports No: ERA-23-338 and ERA-23-339.